



July 22, 2024

LOREN BODLEY
FULFORD TOWN OF - PWSID CO0219292
PO BOX 6384
EAGLE CO 81631

BOIL WATER ADVISORY - TIER 1 PUBLIC NOTIFICATION REQUIREMENT

Dear LOREN BODLEY:

This letter serves as formal notification to the FULFORD TOWN OF (the "Supplier") by the Colorado Department of Public Health and Environment-Water Quality Control Division (the "Department") of the requirement to issue a "Boil Water Advisory" to the users of the public water system. This "Boil Water Advisory" is required as a measure to protect public health due to the lack of treatment for a groundwater source under the direct influence of surface water and the Supplier's failure to monitor for total coliform to assess the water quality. Untreated water may allow disease-causing organisms to enter the water system.

Section 11.33 of Regulation 11: Colorado Primary Drinking Water Regulations 5 CCR 1002-11 (Regulation 11) requires that public notice be delivered to the Supplier's water users as soon as practical and within **twenty-four (24) hours** of receipt of this letter.

To assist you in fulfilling the public notification requirements, enclosed are copies of the Tier 1 Public Notice Instructions, which includes the "Ten Required Elements of a Public Notice", the Public Notification Template, and the Drinking Water Public Notification "Certificate of Delivery" Form. Please fill in the blanks of the template with language to reflect your specific situation. Additionally, public water suppliers are required to submit a certification of delivery following any type of public notification to verify that all associated public notice activities have been completed in accordance with Regulation 11. The "Tier 1 Public Notice" must be reissued every two weeks until the Department has determined the distribution system is operating properly and providing safe drinking water to the public and has provided the Supplier with written correspondence rescinding the advisory.

The boil water advisory shall remain in effect as long as the system is a public water system subject to Regulation 11. In order to rescind the boil water advisory while a public water system, the officials responsible for managing this public water system must:

1. Correct the underlying problem by installing continuous chemical disinfection and maintaining a disinfectant residual of at least 2.0 mg/L at the entry point.
2. Flush the distribution system in consultation with the Department.

3. Obtain three (3) water samples from the affected areas of the distribution system and have them analyzed for the presence of total coliform.

Upon completion of the above actions, the Supplier must provide the Department with a written description of the following activities:

1. What the problem was and the actions taken to correct the underlying problem.
2. Actions and procedures to flush the distribution system, to include:
 - a. Sampling performed and date/time of sampling.
 - b. Disinfection residual results.

In addition, the Supplier must provide the Department with copies of the following:

- "Certificate of Delivery" Form along with a copy of the Public Notice within ten (10) calendar days after each public notice distribution.
- All laboratory and field monitoring results.

Please be advised, in the interest of protecting public health, the "Boil Water Advisory" will not be rescinded until the Supplier has successfully completed the actions described above and received written notice (fax or email) authorizing the rescind of the advisory.

If you have any further questions, please contact me at 303-692-3318 or via email at bryan.pilson@state.co.us.

Sincerely,

Bryan Pilson
Technical, Regulatory Implementation, and Coordination Unit Manager
Water Quality Control Division
Colorado Department of Public Health and Environment

ec:

LOREN BODLEY - butchbodley@comcast.net;

EZRA HARRIS - fulfordtreas@gmail.com;

Claire Lewandowski - claire.lewandowski@eaglecounty.us; Eagle County Environmental Health Dept
Office Email - environment@eaglecounty.us; Eagle County Environmental Health Dept

Nicole Rowan, Water Quality Control Division Director, CDPHE

Ron Falco, WQCD SDW Program Manager

Nathan Moore, WQCD CW Program Manager

Tyson Ingels, WQCD ES Manager

Heather Young, WQCD FSS Manager

Nicole Graziano, WQCD DWCAS Manager

Jorge Delgado, WQCD DWCAS Compliance North Unit Manager

Robert Pohl, WQCD DWCAS Compliance South Unit Manager

Stephanie Hosie, WQCD MHP Unit Manager

MaryAnn Nason, WQCD Administrative Program Manager

Kaitlyn Beekman, WQCD Communication Specialist

Drinking Water Acute Response Team Leads, WQCD

Sean Scott, DEHS, CDPHE

Henry Mitchel. Office of Emergency Preparedness and Response, CDPHE

Curt Drennen, Office of Emergency Preparedness and Response, CDPHE

Korey Bell, Office of Emergency Preparedness and Response, CDPHE
Pam Pergande, Office of Emergency Preparedness and Response, CDPHE
Ria Fears, Office of Emergency Preparedness and Response, CDPHE
Enteric Waterborne Disease Team, DCPHR, CDPHE
Mobile Home Park Oversight Program, DOLA, MHPOP@state.co.us
Tessa Johnson - NORTH - A SW WQCD DWCAS Compliance Specialist

File: CO0219292, EAGLE, Transient, Non-Community - Groundwater UDI Surface Water